



ORIGINAL ISSUE DATE: January 25, 2006

Recertification due: December 2013

An Activity Sponsored and Administered by
Intertek

PROGRAM ADMINISTRATOR
DEPARTMENT ALECP
INTERTEK
ETL SEMKO Division
3933 U.S. ROUTE 11
CORTLAND, NY 13045-0950

AMERACE
A DIVISION OF THOMAS & BETTS
77 WEST BEAVER CREEK RD
RICHMOND HILL, ONTARIO
CANADA L4B 3A7

**AIRPORT LIGHTING
EQUIPMENT
CERTIFICATION PROGRAM**

**CERTIFICATE OF
CONFORMANCE**

The product described below is hereby approved for listing in the next issue of the Federal Aviation Administration (FAA) Advisory Circular (AC) 150/5345-53, Appendix 3 Addendum "Airport Lighting Equipment Certification Program. The approval is based on successful completion of tests in accordance with the specifications listed in, and the requirements for approval described in the Advisory Circular, and the reporting to the Program Administrator the results of such tests, accompanied by related documents by an Intertek recognized testing laboratory. The certification is not valid for a product modified with non-OEM replacements parts or non-production components.

L-830 – Isolation Transformers, 60 Hz (AC 150/5345-47B)					
Manufacturer	Type	Watts	Amperes Pri/Sec	Manufacturer's Catalog Number	
Amerace A Division of Thomas & Betts	L-830-18	150	6.6/6.6	TA150666-01 TA150666-10	

1. This Equipment requires continuing validation in accordance with the requirements of AC 150/5345-53, and the Intertek Airport Lighting Equipment Certification Program.

2. Product tested and Report issued by: Amerace

(A) Report No: 05-16

(B) Date of Report: 12/2005

NOTE: PLEASE REVIEW, AND ADVISE ADMINISTRATOR AT INTERTEK IMMEDIATELY IF DATA, AS SHOWN, NEED TO BE CORRECTED.

Approved for Certification by:

David C. Edwards, Program Administrator

Date: January 25, 2006