

PROGRAM ADMINISTRATOR DEPARTMENT ALECP INTERTEK 3933 U.S. ROUTE 11 CORTLAND, NY 13045-0950

Thomas & Betts Corporation 12 Southland Road Ormond Beach, FL 32174 USA **REVISION DATE: September 14, 2018** 

ORIGINAL ISSUE DATE: December 7, 2015

Recertification due: \_\_July 2023

An Activity Sponsored and Administered by Intertek

## AIRPORT LIGHTING EQUIPMENT CERTIFICATION PROGRAM

## CERTIFICATE OF CONFORMANCE

The product described below is hereby approved for listing in the next issue of the Federal Aviation Administration (FAA) Advisory Circular (AC) 150/5345-53, Appendix 3 Addendum "Airport Lighting Equipment Certification Program. The approval is based on successful completion of tests in accordance with the specifications listed in, and the requirements for approval described in the Advisory Circular, and the reporting to the Program Administrator the results of such tests, accompanied by related documents by an Intertek recognized testing laboratory. This Certificate is only confirmable in conjunction with equipment being listed in AC 150/5345-53, Appendix 3, Addendum, as currently published by the FAA. The certification is not valid for a product modified with non-OEM replacements parts or non-production components.

| L-831 – Isolation Transformers, 50 Hz<br>(AC 150/5345-47C) |         |       |                 |                               |
|--|---------|-------|-----------------|-------------------------------|
| Manufacturer   | Type    | Watts | Amperes Pri/Sec | Manufacturer's Catalog Number |
| Thomas & Betts Corporation<br>Ormond Beach, FL USA         | L-831-8 | 300   | 6.6/20          | TA300625-01<br>TA300625-10    |

- 1. This Equipment requires continuing validation in accordance with the requirements of AC 150/5345-53, and the Intertek Airport Lighting Equipment Certification Program.
- 2. Product tested and Report issued by: Thomas and Betts Ltd.

(A) Report No: 13-15

(B) Date of Report: 8/2015

Approved for Certification by:

NOTE: PLEASE REVIEW, AND ADVISE ADMINISTRATOR AT INTERTEK IMMEDIATELY IF DATA, AS SHOWN, NEED TO BE CORRECTED.

Jeremy N Downs, P.E., Program Administrator

Date: September 14, 2018

Form AL-3 1/2006